Rotary encoder

# HE30B/HB

## **INSTRUCTION MANUAL**

Thank you for purchasing HANYOUNG product.

Please check whether the product is the exactly same as you ordered.

Before using the product, please read this instruction manual carefully.

Please keep this manual where you can view at any time

# HANYOUNGNUX CO.,LTD 1381–3, Juan-Dong, Nam-Gu Incheon, Korea, TEL: (82–32)876–4697 FAX: (82–32)876–4696 http://www.hynux.net

# Safety information

	DANGER indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury
	WARNING indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury
⚠ CAUTION	CAUTION indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury

# ⚠ Warning

 Since this product is not designed as a safely used device the user must install double safety equipment when this product is used for equipment with possible fatal accident or large property damage.

# **⚠** Caution

- · Please check for correct model type and specification,
- · Please check for any damage or abnormality that may occurred during shipment.
- Rotary encoder is composed of very precision parts so impacting strong shock to the product may damage the function therefore, please handle with care.
- · The shield wire of rotary encoder is not connected to the CASE
- If the device is touched or contacted by water then short-circuit and fire may occur so please inspect the device with care
- We recommend the continuous inspection and repair in order to use it safely for a long period of time,
- · Not following this instruction manual may result in personal injury and property damage.

#### ■ About Mega Test

 Although it has an internal voltage 800 V d.c in between the CASE and electric circuit, internal electric circuit may get damaged or destroyed if users use wrong method when applying the voltage. Therefore, please do not perform the mega test.

#### ■ About Installation

- · When installing, do not apply strong force or twist the rotational axis of encoder.
- The life expectancy of rotary encoder varies depending on the using condition or environment so please be cautious
- · Do not disassemble, manufacture, upgrade and repair the product by yourself.
- Please turn OFF the product and disassemble the product. Not doing so will break down the product and cause malfunction to occur.
- Rotary encoder is composed of very precision parts so impacting strong shock to the product may damage the function therefore, please handle with care.
- When installing the rotational axis of rotary to the device, please use the Coupling and when installing the Coupling to axis, do not apply strong force.
- When mounting the product, as the eccentricity and angle deviation become larger, the force applied to the shaft will become large too and result may damage the product or shorten the life expectancy.

#### ■ About Environment.

Please avoid using this product at following environment. Doing so may break down the product or cause malfunction to occur.

- Place where the internal parts or structure become damaged by the strong vibration and shock
- Place near to the machine which generates the strong electromagnetism or electrical noise
- Place that does not fall into the given specification especially for ambient temperature and humidity.


## ■ About wiring

- Please separate the input signal wire and output signal wire from each other but when separating them from each other is impossible, please use the shield wire for input wire.
- When there are too much noises generating from the power, we recommend using the insulation Trans and noise filter
- Please check the polarity of terminal before wiring.
- · Please make the wiring length as short as possible
- Wiring the rotary encoder wire and power wire to each other may cause malfunction to occur so please be cautious.
- · False wiring of rotary encoder may break down the internal circuit so please be cautious
- If type for applying power is SMPS, surge may occur so please connect noise filter (surge observer) to the power terminal and doing so will solve the problem that corresponds to the surge. Also, in order to minimize the effect causing by noise and etc, please make the wiring as short as possible.
- When extending or drawing out the cable, please use the Twist Pair wire.
   Shield wire must be connected to the F.G terminal!

#### About the vibration

- If strong vibration or shock is carried out through the rotary encoder, incorrect pulse may be generated and this may end up as malfunction of system so please be cautious about the installation place, mounting place and etc.
- As there are much of pulse generation per 1 rotation, the slit gap of rotational slit gets narrower so it may be influenced by vibration easily and the vibration applied during spinning or when it is stopped, it will be carried through out this device so may generate the wrong pulse so please be cautious.
- When inserting the coupling to Shaft, do not apply shock by using the hammer and etc.

#### ■ About the Noise



Distance from the control panel	Connection method of rotary encoder
	For the case of rotary encoder, please connect it to the controlling case
More than 30m	with wire type 3 - 5.5 mm². For the 0 V (E) terminal, please connect it to the
	controlling case with the same type of wire and ground it one more time.
Less than 30m	Refer to the information on the above and ground the rotary encoder.

\* Not following the information on the above when handling the product may damage the product so please follow it at all times,

#### Suffix code

Suitix code											
Model			Code				Information				
HE30		□ □ □ □ □ □ Ø30 mm rotary encoder. Incremental				coder, Incremental					
	В	4		į .	İ	i L	Shaft	Axis: Ø4 mm			
Dimension	НВ	2 ¦		İ	l	l I	Inner diameter: Ø2 mm				
Dillension		2,5		1			Blind shaft	Inner diameter : Ø2,5 mm			
		3						Inner diameter : Ø3 mm			
	100										
			200			i i	Niveles of rules and arrival time				
Number	of		360			l					
Pulse			500	İ		!	Number of pulse per 1 revolution				
			1000	1							
				1	   						
	2				I	A, B phase output					
				3			A, B, Z phase output				
Output s	signa	al		3C		i I	A, B, Z phase output				
	4			4			A, A, B, B phase output				
				6			A, A, B, B, Z, Z phase output				
						12	NPN voltage output (5 - 12 V d.c)				
					N	24	NPN voltage output (12 - 24 V d.c)				
						12	NPN open collect	open collector output (5 - 12 V d.c)			
Output circuit				0	24	NPN open collector output (12 - 24 V d.c)					
				_	12	Totempole output	e output (5 - 12 V d.c)				
				Т	24	Totempole output (12 - 24 V d.c)					
					L		Line Driver output (5 V d.c)				


# Specification

Model		HE30B-4N-	HE30B-40-	HE30B-4-0-0-T-0	HE30B-45			
	Model	HE30HB	HE30HB-0-0-0-0	HE30HB	HE30HB5			
C	Output type	NPN Voltage output	NPN Open collector output	Totem Pole output	Line Drive output			
	Output type	A Phase	A,B,Z,Ā,B,Z Phase					
	Phase difference	Phase difference between A, B phase						
	on Output	$T/4 \pm T/8$ (Cycle of A phase = T)						
	Max Response	000 111						
اڃ	Frequency	300 kHz						
Specification	Power Voltage	5 – 12 V c	5 V d.c ±5 %					
Sij.	Current Consumption	60 mA Max.(No-load) Line Drive output below 50 mA (No-load)						
Spe	Connection method	Cable extended type						
g				For Low	For Low			
Electrical		Load voltage :	30 V max	Load Current: 30 nA max, Remaining Voltage:	Load Current: 20 nA max, Remaining Voltage:			
==	Control output	Load Current : 3		0.4 V max.	0.4 V max.			
		Remaining Volta		For High	For High			
		0.4 V d.c max.	0 -	Load Current: 10 nA max.	Load Current : 20 nA max.			
		5, 5,0		Remaining Voltage:	Remaining Voltage:			
				Power Voltage - 2,5 V min,	2,5 V min.			
	Response Time	Response Time 1 µs max. (Cable length 1.5 m, sinking current = 20 mA max.)						


cation	Starting Torque	0.002 N·m max.			
Mechanical Specification	Moment of inertia	2×10 <sup>-6</sup> kg · m² max.			
anical	Permissible	Radial: With in 15 N, Thrust: With in 10 N			
Mech	Shaft Loading	Radial - Willi III 15 N, Tillust - Willi III 10 N			
	max. Permissible Revolution	5000 r/min			
Insulation Resistance		Over 100 Mg (Base on 500 V d.c mega between terminal and case)			
Dielectric strenght		800 V a.c (Between terminal and case at 60 Hz for 1 minute)			
Vibration Resistance		10 – 55 Hz(Cycle for 1 minute), Double amplitude width : 1.5 mm, Each X $\cdot$ Y $\cdot$ Z direction for 2 hours			
Shock Resistance		490 <b>%</b> max.			
Ambient		-10 $\sim$ 70 $^{\circ}$ C (Without condensation),			
Temperature		When storage: -25 ~ 85 °C			
Ambient Humidity		35 $\sim$ 85 % R.H., When storage : 35 $\sim$ 90 % R.H.			
Wire		5 P, Ø 5.0 mm, Length: 1.5 m, Shield cable			
Specification		(Line Driver Type: 8P, Ø 5.0 mm, Length: 1.5 m, Shield cable)			
	Weignt	Approx. 120 g (included the weight of box)			
Accessory		HE30B(Shaft): Ø4.0 mm Coupling, HE30B(Hollow and blind shaft): Bracket			

Dimension


[Unit : mm]



■ Accessories (Ø4 Coupling)




#### ■ HE30HB




## Wiring Diagram

■ Voltage output, Totem Pole output, Open collector output




■ Line Driver Output



\* Please insulate unused lines

\* Metal case of encoder and Shield line must be ground connection


# Control output circuit diagram




\*\* The output circuit of A, B, Z Phase (Line drive output A,  $\overline{A}$ , B,  $\overline{B}$ , Z,  $\overline{Z}$  Phase) is same.

## Output wave -

■ NPN Voltage output, NPN Open Collector Output, Totem Pole output



#### ■ Line Driver Output



★Clockwise (CW): When you are looking at the shaft of the product, it is turning in a clockwise direction.
★Counterclockwise (CCW): When you are looking at the shaft of the product, it is turning in a counterclockwise,